

BID ADDENDUM

Date: May 11, 2015

To: All Prospective Bidders – **Bid #15-21 Supply & Install an Intrusion Detection System**

From: Michelle Enman, Purchasing Agent

Subject: **Bid Addendum #1**

Attached please find Addendum #1 for the above referenced project. Also, because of this Addendum, the bid due date has been extended to Monday, May 18, 2015 with the opening to take place at 11am. All bids must be in purchasing by that time.

To submit a bid, please use the original Bid Sheet on the RFP. Please contact me at 860-291-7271 or menman@easthartfordct.gov with any questions that you may have. Thank you.

DATE: May 10, 2015

**RFP 15-21: Supply and Install a Intrusion Detection System
Addendum #1**

Intrusion Detection RFI

Q1. Are all devices run back to the server room in the basement?

A1. Yes

Q2. Will each device be counted as an individual zone?

A2. Zones shall be determined with the client. All devices are cabled as "home-runs".

Q3. Please define wire to connect to fire alarm panel.

A3. Provide #18-4 Conductor control cable is required form the Honeywell panel in server room to the King Fisher, Fire alarm panel located on the second floor #IT Room. There is a conduit from the Server room in the basement to this IT Room.

Intrusion Detection Clarifications to Bid Manual

1. Specification 28 16 00 - 10, Article 2.2 COMMUNICATION DEVICE; Remove the **HONEYWELL #GSMV4G** or equivalent Digital Cellular Communicator for VISTA Control Panels from this project.

Submission requirement:

- Please include an electronic (PDF) version of your bid on CD.