



Town of East Hartford

ADDENDUM N^o. 1

**PITKIN STREET SIDEWALK REPLACEMENT
Bid No. 21-08**

Issued January 27, 2021

The following summarizes revisions to the Bid Documents included in Addendum N^o. 1 for the PITKIN STREET SIDEWALK REPLACEMENT (Bid No. 21-08).

- The pre-bid meeting was on Thursday, January 21, 2021. Questions raised at the pre-bid meeting, and responses, follow:

1. How do I contact Sara Ross from the Grants Department?

Answer: *Sara can be reached at (860) 291-7210 or sross@easthartfordct.gov.*

2. How do I find the certified payroll form?

Answer: *Link to certified payroll form:*

<http://www.dol.gov/whd/forms/wh347.pdf>

Link to directions on how to complete certified payroll form:

<http://www.dol.gov/whd/forms/wh347instr.htm>

Link to Contractor's Guide to Prevailing Wage Requirements for Federally-Assisted Construction Projects: Making Davis-Bacon Work:

<https://www.hudexchange.info/resource/2541/making-davis-bacon-work-contractors-guide-prevailing-wage-requirements/>

3. Is all curbing new?

Answer: *Yes.*

4. Is all curbing granite?

Answer: *Yes, except where the curb is integral with the sidewalk.*

5. How does it transition at driveway aprons?

Answer: *Please see the curb detail in the revised drawings.*

6. Can you confirm that installation of curb at ramp areas have a concrete base and all other areas curb is set on process [aggregate]?

Answer: Please see the granite curb section A-A on sheet 6 of the revised drawings.

- The plans were sent to the Connecticut Department of Transportation for preliminary review on Tuesday, January 19, 2021. They responded with the following changes, which are reflected in the Revised Drawings:
 - In the prints, I will need to see construction notes that state that all catch basins will be protected, all pavement markings will be painted with epoxy paint to State specs, and that all compaction will conform to the State of Connecticut Department of Transportation Form 818.
 - Construction Notes have been added to the Cover Sheet of the Drawings.
 - Also, include in the set of prints the detail sheet showing pavement repair labeled (Encroachment Permit – Pavement Repair).
 - Please make sure the contractor you choose is aware that they have to apply for a permit with a fee of \$50.00 a minimum bond of \$10,000 and insurance for \$1,000,000.00 for each accident and aggregate of \$2,000,000.00.

The following documents & drawings are attached and included in Addendum N^o. 1:

Revised Bid Documents

- N/A

Revised Drawings

- Replace Cover Sheet (Sheet 1).
- Add sheets 6 and 7.

End of Addendum N^o. 1