



Town of East Hartford

ADDENDUM N^o. 02

**Meadow Hill Sanitary Sewer Holding Tank Project
Bid No. 22-06**

Issued October 20, 2021

The following lists answers to inquiries made during the Non-Mandatory pre-bid meeting on October 14, 2021 for the Meadow Hill Sanitary Sewer Holding Tank Project (Bid No. 22-06).

- Q. Are hazardous chemicals present in the waste piping coating scheduled removed?
 - A. The Town is not aware of nor, do we anticipate there to be any, hazardous materials in the building materials impacted by the Work.
- Q. What is the depth and maximum loading on the 42” RCP sewer mains to the south of the pump station?
 - A. The MDC requires adequate protection of the sewer outfall pipe during construction. The two outfalls are located approximately 5 and 10 feet below grade respectively. The contractor should notify the MDC before starting work.

The following documents & drawings are attached and included in Addendum N^o. 02:

Revised Bid Documents

- None

End of Addendum N^o. 02